



Government of Odisha

Phone / Fax – (06856) 222149
E-mail – eepwd765001@gmail.com

**OFFICE OF THE EXECUTIVE ENGINEER
RAYAGADA R&B DIVISION NO-I, RAYAGADA**

Letter No. 5188

Date. 09-10-2020

To,

The Principal
Kendriya Vidyalaya,
Rayagada

Sub :- Submission of Safety Certificate of school building of Kendriya Vidyalaya Rayagada

Sir,

In inviting a reference on the subject cited above, it is to certify that the Educational Institute of Kendriya Vidyalaya Rayagada is structurally safe under normal condition.

Yours faithfully,

Executive Engineer,
Rayagada (R&B) Division No-I

Memo No

Dt

Copy to the Assistant Executive Engineer, Rayagada (R&B) Sub-Division No-II for information and necessary action.

Executive Engineer,
Rayagada (R&B) Division No-I

GSTIN/UIN : 21AUDPR1874L1ZF

SAMPARK FIRE & SAFETY

Beside Indian Overseas Bank, New Colony, Rayagada- 765 001

Ph : 06856- 223648 (Off.), Cell : 9777554400

E-mail : samparkfire.safety@gmail.com

Sl. No. 184.....

CERTIFICATE



To

M/s. Kendriya Vidyalaya

Rayagada

1. Type of Fire Extinguisher

1. DCP -
2. Mechanical Foam -
3. Water CO₂ -
4. CO₂ 4.5 kg - 1 no - Tested
5. ABC 6 kg - 04 nos - Refilled, 5 kg - 1 no - Refilled
6 kg - 10 nos - Tested, 2 kg - 1 no - Tested
5 kg - 05 nos - Tested

2. Refilling / Checking on dated 05-02-2021.....
3. Next Refilling Due Date on 02-02-2022.....
4. Hydraulic Testing on Date 05-02-2021.....
5. Remarks (O.K.).....

SAMPARK FIRE & SAFETY
RAYAGADA
Signature

SAFETY IS OUR MOTTO

OFFICE OF THE EXECUTIVE ENGINEER
RWS&S DIVISION, RAYAGADA

Letter No: 3357

Date: 5.9.2019

To,

The Principal,
Kendriya Vidyalaya, Rayagada.

Sub: Submission of water sample test report.

Sir,

With reference to above cited subject, I am submitting herewith the water sample test report of 02 Nos of samples submitted by you.

This is for favour of your kind information and necessary action.

Yours faithfully



Encl: Test Report 1 set


Executive Engineer
RWS&S Division, Rayagada

our
to file

Sl. No	Date of Testing	Source Type	Block	G.P	Village	Habitation	Location	Test Results				
								Fe (1.00 Mg/l)	Cl (1000 mg/l)	F (1.0 Mg/l)	ph (6.5 - 8.5)	Bact. Cont (-ve)
1	22.08.19	Tap Water	RAYAGADA	RAYAGADA	JAYARAMGUDA	KENDRIYA VIDYALAYA	KENDRIYA VIDYALAYA	0.26	120	0.00	7.86	+ve
2	22.08.19	AG	RAYAGADA	RAYAGADA	JAYARAMGUDA	KENDRIYA VIDYALAYA	KENDRIYA VIDYALAYA	0.00	80	0.00	6.70	-ve

Test Reports Produced are of the samples collected and submitted by school authorities.

Junior  Assistant
RWS&S  Rayagada